

**CITY OF FREMONT, NEBRASKA  
CITY FIREWORKS LICENSE APPLICATION**

A license to sell fireworks within the city limits of Fremont has been requested and a fee of \$ \_\_\_\_\_ has been paid to the City Clerk.

JOBBER: \_\_\_\_\_ JOBBER LIC #: \_\_\_\_\_

STATE LIC HOLDER: \_\_\_\_\_

STATE LIC #: \_\_\_\_\_

DATE: \_\_\_\_\_ RECEIVED BY: \_\_\_\_\_

\*\*\*\*\*

**FREMONT FIRE DEPARTMENT**

415 E 16<sup>th</sup> Street, Fremont NE 68025  
402-727-2688 (Fax 402/727-2829)

**FIREWORKS STAND INSPECTION FORM**

**Stand Location:** \_\_\_\_\_

**Contact Person & Phone #:** \_\_\_\_\_

All of the following requirements must be made prior to opening your stand. Those items not checked off must be brought into compliance before a City license will be issued.

\_\_\_\_\_ The fireworks stand is constructed of steel or at least 3/8" plywood, or equivalent with two-by-four studding.

\_\_\_\_\_ The fireworks stand or enclosure does not exceed five hundred square feet in size.

\_\_\_\_\_ The stand has installed the required signage.

\_\_\_\_\_ The fireworks stand is located on a paved surface in a commercially or industrially zoned district

\_\_\_\_\_ The fireworks stand is 50 ft away from any buildings and 100 ft away from any service stations or facility where gasoline or oil is sold.

\_\_\_\_\_ The fireworks stand is 2 ft inside the sidewalk or an equivalent distance from the street curb so patrons do not hamper normal walk ways

YES / NO ON THE DATE OF INSPECTION, THIS STAND MEETS THE NECESSARY LOCATION REQUIREMENTS

If “NO”, the unchecked requirements MUST BE MADE before a City license will be issued!

DATE: \_\_\_\_\_ INSPECTED BY: \_\_\_\_\_

COMMENTS: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

**The stand owner understands that at least one competent person 18 yrs or older shall be in attendance at ALL times while the stand is open for business, to be responsible for all life and property.**

**ALL FIREWORKS SHALL BE STORED OUT OF REACH OF THE PUBLIC! NO MATCHES WILL BE STORED, SOLD OR GIVEN AWAY AT THE FIREWORKS STAND.**

**The owner also understands that the following signs must be posted:**

**A “NO SMOKING WITHIN 50 FEET” sign is posted conspicuously on the stand in 3 separate locations with at least 2-1/2” lettering**

**A “FREMONT MUNICIPAL CODE ALLOWS FIREWORKS TO BE DISCHARGED ONLY ON THE FOLLOWING DATES AND TIMES” sign is posted with at least 2-1/2” lettering**

**A “NO DISCHARGING OF FIREWORKS WITHIN 300 FT OF STAND” sign is posted with at least 2-1/2” lettering**

**A “NO PARKING WITHIN 12 FT” sign is posted. No unattended vehicle shall be parked within 12 ft of the stand.**

**At least one (1) multipurpose portable FIRE EXTINGUISHER shall be furnished and maintained in all areas used for the sale and storage of fireworks. The extinguisher shall have a rating of at least 4-A for Class A fires. Two (2) stored pressure water extinguishers with a capacity of at least 2-1/2 gallons each may be substituted for multipurpose extinguishers. The fire extinguisher(s) shall be available at all times, and will be mounted conspicuously not more than 5 ft from the floor to the top of the extinguisher and just inside the walk in door. All personnel must be instructed in proper extinguishing procedures.**

**THE STAND OWNER ALSO UNDERSTANDS THAT THE STAND WILL BE REMOVED FROM ITS TEMPORARY LOCATION WITHIN TEN (10) CALENDAR DAYS OF THE LAST DAY OF SALE (JULY 4<sup>th</sup>). Fireworks may be sold at retail between 12:01 a.m., June 27<sup>th</sup> and midnight, July 4<sup>th</sup>.**

*(Owner’s signature to be obtained after the inspection is made.)*

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature of Owner (or Designee)